

1. The Indicators for Supply Quality Measures and Grid Security Performance for 2021.

- a. Average Interruption Time (AIT) ,35 minutes.
- b. Energy not Supplied (ENS) 467 MWh.
- c. Notification Period for the Planned Interruptions in the Transmission System, 72 hours.
- d. Response Time to New Connection Request, within 60 days.
- e. System Average Interruption Duration Index (SAIDI) 104 minutes.
- f. Voltage Quality (VQ), as defined in Article 38 of the Transmission Code.
- g. Percentage of the Complaints for Voltage Quality, 0%